



**Drinking Water Quality and Compliance  
for The Town of Vonda  
2022 Annual Notice to Consumers**

### Introduction

The Water Security Agency (WSA) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a Waterworks. The following is a summary of the Town of Vonda water quality and sample submission compliance record for the January 1, 2022 to December 31, 2022 time period. This report was completed on January 2, 2023. Readers should refer to the Agency's [Municipal Drinking Water Quality Monitoring Guidelines, October 2020, EPB 202](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards

#### Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	24	24	0

#### Water Disinfection -

#### Chlorine Residual In Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	1.19 – 1.68	1.00 – 1.50	24	24	100%

#### Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.61 – 1.81	365	0

A minimum of 0.1 milligrams per liter (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

#### Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0	0.09 – 0.56	0	0.56	365	365

### Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for WSA's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on May 21, 2021. Sample results indicated the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0025	0	* Results expressed as average values
Barium	1.0		0.0007	0	for communities or
Boron		5.0	0.06	0	waterworks that
Cadmium	0.005		< 0.00001	0	fluoridate drinking
Chromium	0.05		< 0.0005	0	water supplies or
Fluoride (avg*)	1.5		< 0.01	0	those with elevated
Lead	0.01		< 0.0001	0	concentrations of
Nitrate (avg*)	45.0		< 0.04	0	fluoride or nitrates.
Selenium	0.01		< 0.0002	0	
Uranium	0.02		< 0.0001	0	

### General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	92	1	1
Bicarbonate	No Objective	112	1	1
Calcium	No Objective	3.0	1	1
Carbonate	No Objective	< 1	1	1
Chloride	250	3.1	1	1
Conductivity	No Objective	201	1	1
Hardness	800	13	1	1
Magnesium	200	1.4	1	1
pH	No Objective	7.90	1	1
Sodium	300	38	1	1
Sulphate	500	10	1	1
Total dissolved Solids	1500	131	1	1

All waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as  $\text{CaCO}_3$ ), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in 2021 and was submitted on May 21. Sample results indicated there were no exceedances of the provincial aesthetic objectives for the General Chemical category.

\*Objectives apply to certain characteristics of substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as  $\text{CaCO}_3$ , magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

Town of Vonda  
Box 308  
Vonda, Saskatchewan  
S0K 4N0  
(306)258-2035  
vondatown@sasktel.net