

July 10, 2026**306-860-7395**

Via Email: office@thetownofvonda.com

Vonda
Box 308
Vonda, SK S0K 4N0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Vonda: 2nd Street between Buffer Ave and Railway Ave* - Rescinded

The Water Security Agency, is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Vonda*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of two (4 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-860-7395 or kim.driedger@wsask.ca.

Sincerely,



Kim Driedger
Environment Officer
Water Security Agency

cc: Lee Reinhart, Supervisor, Compliance Promotion North, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Saskatoon Office